
DESCRIPTION 154R-105050 REV.:6 05/23/23 DATE

KIT PART NUMBER	CABLE LENGTH (FT.)	CABLE COLOR	MAX. TENSION ALLOWABLE (LBS.)	KIT TYPE
SB-250-LRC-513	13	GREEN	2667 OR 2184	15/16" SLOT / 11/16" ANCHOR BRACKET
SB-250-LRC-510	10	GREEN	2667 OR 2184	15/16" SLOT / 11/16" ANCHOR BRACKET
SB-250-LRC-507	7	GREEN	2667 OR 2184	15/16" SLOT / 11/16" ANCHOR BRACKET

- A. RATING AT 45° FOR STEEL ATTACHMENT (LRFD) 2667#
- RATING AT 45° FOR CONCRETE ATTACHMENT- 5/8" HILTI TZ @3-1/8" EMBEDMENT, 5" SLAB MIN 2184#



- QTY (2) SB-250 Ø15/16" SLOTTED BRACKETS WITH EACH BRACKET ASSEMBLY COMPRISED OF (2) 3/4" BOLTS & (2) 3/4" SERRATED LOCK NUTS.
- 4. FIELD TORQUE 3/4" LOCK NUTS TO 50 FT-LBS.
- 5. FM APPROVAL APPLIES ONLY TO INSTALLATIONS USING STRUT OR ANGLE.

OTHER MATERIALS, COMPOUNDS, OR FINISHES WITH EQUAL OR SUPERIOR PROPERTIES MAY BE SUBSTITUTED AS THEY BECOME AVAILABLE.



SB-250 BRACKET Ø15/16" SLOT

EQUIPMENT ATTACHMENT

CERTIFIED FOR:

JOB NAME:

CUSTOMER P.O.:

SALES ORDER:

CUSTOMER:

MODEL SB-250-LRC 2667 LBS. 3/16 INCH GREEN SEISMIC CABLE RESTRAINT KIT



Bloomingdale, NJ 07403

Houston, TX 77041

1 OF 1

SHEET:

NONE

THE POWER OF TOGETHER

DRAWING NO.: REVISION

LOOP CABLE

HEAD OF BOLT

EQUIPMENT¹

- UNDER & AROUND