174R-102827 REV.: 2 REV. DESCRIPTION DATE BY - 3/8 x 1 1/2 RUBBER GASKET SCREW DOWN EVERY 2 FEET UNIT OVERHANG 0 20 GAGE UPPER FLASHING SHIPPED LOOSE AND FIELD INSTALLED RUBBER GASKET TO ENCLOSE ENTIRE OUTSIDE OF CURB. - 3/8 TYP. AIR GAP SHIPPED LOOSE AND FIELD INSTALLED 3/8 SHIPPING SPACER (REMOVED DURING INSIDE CURB --INSTALLATION) 20 GAGE LOWER FLASHING SHIPPED LOOSE AND FIELD INSTALLED TO WOOD NAILER 21 1/8 0 2 X 2 (1.5 X 1.5) CCA40 TREATED -WOOD NAILER ALL AROUND CURB 0 2" THICK INSULATION BOARD B.O. WATER PROOF MEMBRANE B.O. 0 OPTIONAL CANT STRIP B.O. ROOF ROOF **SECTION VIEW A-A** NOTE: 1. B.O. = BY OTHERS NOT BY THE VMC GROUP OTHER MATERIALS, COMPOUNDS, OR FINISHES WITH EQUAL OR SUPERIOR PROPERTIES MAY BE SUBSTITUTED AS THEY BECOME AVAILABLE. **CERTIFIED FOR:** NONE MODEL TELECURB JOB NAME: _ SHEET: **ISOLATED** CUSTOMER: NON-SEISMIC WIND RESTRAINT

DETAILS AND SECTIONS

CUSTOMER P.O.:

SALES ORDER:

THE VMC GROUP DRAWING NO.:

The Power of Together Bloomingdale, NJ 07403

Houston, TX 77041

REVISION