



## Type 4

### Elastomeric Hanger

---

Elastomeric Hangers shall consist of an elastomeric element installed into a steel hanger box. Element shall have a minimum static deflection of 0.4". Hanger box shall be provided with holes top and bottom to attach hanger rods. Hanger box shall be either epoxy powder coated steel or be made from galvanized steel sheet metal. The elastomeric element shall have resilient bushings projecting through the box.

**The VMC Group**

Headquarters: 113 Main Street • Bloomingdale, NJ 07403 | Houston: 11930 Brittmoore Park Drive • Houston, TX 77041

Phone: 973.838.1780 | Toll Free: 800.569.8423

[www.themcgroup.com](http://www.themcgroup.com)